



# INSPECTION REPORT

Q-Lab Test Services

This inspection report contains only findings and results arrived at after employing the specific test procedures listed in the Test Confirmation. It does not constitute a recommendation for, endorsement of, or certification of the product or material tested. Q-Lab Test Services makes no warranty, expressed or implied, except that the test has been performed, and a report prepared, based upon the specimen or specimens furnished by the client. Extrapolation of data from the specimen or specimens relating to the batch or lot from which it was obtained may not correlate and should be interpreted accordingly with extreme caution. Measurement uncertainty is not considered when stating conformity to specified performance requirements. We assume no responsibility for variations in quality, composition, appearance, performance, or other feature of similar subject matter produced by other persons or under conditions over which we have no control. This report shall not be reproduced except in full without the written approval of Q-Lab Test Services.

**CLIENT:** Lightweight Tiles, Ltd.  
**ADDRESS:** Unit 138, Lydney Industrial Estate, Harbour Road, Lydney  
Gloucestershire GL15 4EJ  
UNITED KINGDOM

**TEST NO:** LTL-1

**REPORT NO:** 2

**DATE:** 5 January 2022

**DATE EXPOSED:** 5 January 2021

**DURATION:** 12 Months

**TYPE:** Direct Inland, 5° South-Florida

**SPECIMENS:** 4 Coated roof specimens

**RADIATION LOG:** TOTAL = 6,448.18 MJ/m<sup>2</sup>  
TUVR = 348.14 MJ/m<sup>2</sup>

**NOTES:** Please refer to the legend located on our website at [www.myweathertest.com](http://www.myweathertest.com) for an explanation of the ratings used in this report.

**Any sign of brittleness will be noted in the Comments section.**

**ATTN:** Mr. Bruce Bennett

**YOUR REFERENCE:**

**CONTENTS:** Cover Sheet: Page 1  
Report: Page 2

**Inspected By:** Marie Jones *Marie Jones*

**Approved By:** Ana Ferrera *Ana Ferrera*

